



January 13, 2023

**Contract 2023-02
Tylersville Road**

Addendum #2

BID DATE CHANGE (Updated Meeting Link):

All SEALED BIDS must be received by the Butler County Engineer not later than 10:30 a.m. local time on Thursday, **January 24, 2022**. All timely received SEALED BIDS will be publicly opened at approximately 10:45 a.m. on that date in the Main Conference room at the Butler County Engineer's Office, 1921 Fairgrove Avenue, Hamilton, Ohio 45011-1965.

This meeting will be held at the Butler County Engineer's Office or you may attend virtually using the information provided.

Tue, Jan 24, 2023 10:30 AM - 11:30 AM (EST)

Please join my meeting from your computer, tablet or smartphone.

<https://meet.goto.com/486721765>

You can also dial in using your phone.

(For supported devices, tap a one-touch number below to join instantly.)

United States: +1 (872) 240-3212

- One-touch: <tel:+18722403212>, [486721765#](tel:+18722403212)

Access Code: 486-721-765

Get the app now and be ready when your first meeting starts: <https://meet.goto.com/install>

NOTE CHANGE:

Special: "Contract Time Line"

Description: This project will have a completion date of **September 15, 2023** with liquidated damages set in specification 108.07.

Contract start date: May 1, 2023

Contract completion: September 15, 2023

ADD NOTE:

Temporary Pavement Wedge

Temporary pavement wedges shall be provided at all times where traffic is required to travel from or onto a pavement surface of a different elevation, around manholes, at catch basins, etc. The minimum slope of the temporary pavement wedge shall be 3:1 along longitudinal joints and 120:1 at transverse joints. These wedges shall be removed prior to placing the specified final pavement course. Payment for all work, materials etc. associated with this item shall be paid for under Item 614 Maintaining Traffic, Lump Sum.



Clarification(s)

Q1: How many 5 day closures are permitted?

A1: 1 - 5 day closure is permitted per the notes on sheet 8/92.

Q2: Can other work be completed during the closure?

A2: Yes. Please refer to the "Alternate Methods" note on page 7/92.

Q3: Can the phasing be changed to allow for material supply concerns?

A3: Yes. Please refer to the "Alternate Methods" note on page 7/92.

Q4: Can Price Adjustments be added into the project?

A4: No.

**Please e-mail or call our office when you have received this Addendum.
taylor@mceo.org
Melissa Taylor; 513-785-4115**