



May 4, 2023

**Contract 2023-11
Liberty Way @ Cox Road , Phase 2**

Clarification #1

Clarification(s):

Q1: Its my understanding that only the West approach will require the High Density Polyurethane Grout injection. The East approach will be repaired with more conventual means of correcting the elevations.

A1: Correct

Q2: Also, is there any additional information on the SS 842 spec they are wanting for this project? The standard SS 842 is for typical approach slab jacking by drilling just through the approach slab and injecting. The details provided are asking for the deep injection procedure which is quite more involved.

A2: Please bid per SS842 and the contract documents. Deep injection procedure is not required.

Please e-mail or call our office when you have received this Clarification.

taylor@m@bceo.org

Melissa Taylor; 513-785-4115